



# WEST MILFORD PUBLIC SCHOOLS

46 Highlander Drive, West Milford, New Jersey 07480  
Phone: 973-697-1700 www.wmtps.org Fax: 973-697-8351

Alex Anemone, Ed.D.  
Superintendent

Barbara Francisco  
Business Administrator/Board Secretary

Daniel Novak  
Director of Education

Elizabeth McQuaid, OTD  
Director of Special Services

***“Success Starts Here”***

June 30, 2022

West Milford Board of Education  
West Milford High School  
67 Highlander Drive  
West Milford, NJ 07480

Dear West Milford High School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and in compliance with the Department of Education regulations, West Milford Board of Education tested our schools’ drinking water for lead in June, 2022.

In accordance with the Department of Education regulations, West Milford High School will implement immediate remedial measures for any drinking water outlet with a result greater than the US Environmental Protection Agency established action level of 15 ug/l (parts per billion [ppb]) for lead. This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a “DO NOT DRINK – SAFE FOR HANDWASHING ONLY” sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within West Milford Board of Education. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 26 samples taken, all but 3 tested below the lead action level of 15 ppb.

The table below identifies the drinking water outlets that tested above 15 ppb for lead, the actual lead level, and what temporary remedial action West Milford Board of Education has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in $\mu\text{g/l}$ (ppb)	Remedial Action
Upper Library Office Outlet ID #G-63	56.1	Disabled outlet pending results of flushed sample

Kitchen Prep Room Sink – Single Sink Outlet ID #G-26	24.9	Disabled outlet pending results of flushed sample
Trainers Office Sink in Gym Outlet ID #G-49	157	Disabled outlet pending permanent removal
Rm. 206 Faucet next to Emerg. Shower-Science Lab Outlet ID #G-58	316	Cannot disable – Posted signage “DO NOT DRINK-SAFE FOR HANDWASHING ONLY”

### Health Effects of Lead

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother’s bones, which may affect brain development.

In other words, it is the fetus that is at risk because developing fetuses receive lead from the mother’s bones. Children and fetuses absorb more lead into their bodies than adults and are more susceptible to its effects on brain development; however, most children with elevated blood lead levels do not exhibit any symptoms, but effects may appear later in life.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, pipes made of or lined with lead.

When water remains in contact with lead pipes or plumbing materials containing lead over time, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, may contain elevated levels of lead.

- Homes and buildings in New Jersey built before 1987 are more likely to have lead pipes and/or lead solder.
- Service lines, which may also contain lead, are the individual pipes that run from the well to a home or building. The property owner may also be the owner of the service line. Lead service lines are not typically found in non-community systems (e.g., school, office, restaurant, or other buildings on their own well).

- Brass faucets, fittings, and valves, including those advertised as “lead-free”, may also contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, that contain a maximum of 0.25 percent lead to be labeled as “lead free”. However, prior to January 4, 2014, “lead free” allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Consumers should be aware of their current fixtures and take appropriate precautions.

### Lead in Drinking Water

Lead is a common metal found in the environment. Drinking water is one possible source of lead exposure. The main sources of lead exposure are lead-based paint and lead-contaminated dust or soil. In addition, lead can be found in certain types of pottery, pewter, brass fixtures, cosmetics, imported spices and other food. Other sources include exposure in the workplace and exposure from certain hobbies like shooting ranges and fishing (lead can be carried on clothing or shoes). Lead is found in some toys, some playground equipment, and some children’s metal jewelry.

EPA estimates that 10 to 20 percent of a person’s potential exposure to lead may come from drinking water. Infants who consume mostly formula mixed with lead-containing water may receive 40 to 60 percent of their exposure to lead from drinking water. When there are elevated levels of lead in your water, drinking water is likely to be a more important source of exposure.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8 a.m. and 4 p.m. and are also available on our website at [www.wmtps.org](http://www.wmtps.org). For more information about water quality in our schools, contact Chris Kelly, C.E.F.M., Supervisor of Buildings and Grounds, (973) 697-1700 x 5071.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA’s Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD or Safe Drinking Water Act hotline at 1-800-426-4791, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Dr. Alex Anemone, Ed.D.  
Superintendent of Schools



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: June 27, 2022
Client: West Milford High School
Address: 67 Highlander Dr.
West Milford, NJ 07480

Analytical Results

PWSID#:
Project Location:

Table with sample details: Sample Matrix (Drinking Water), Sample Location (Field Blank), Sampled By (Client), Sample Date/Time (6/3/2022 5:10), Lab Sample Number (220531059-001), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row 1: Lead-1st Draw, SM3113B, < 2.00, µg/L, 15, 6/24/2022, 10:50, JGW, 2, 1.

Table with sample details: Sample Matrix (Drinking Water), Sample Location (G-5), Sampled By (Client), Sample Date/Time (6/3/2022 5:36), Lab Sample Number (220531059-002), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row 1: Lead-1st Draw, SM3113B, < 2.00, µg/L, 15, 6/21/2022, 19:01, JGW, 2, 1.

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-003
Sample Location:	G-7	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:40		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	19:18	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-004
Sample Location:	G-8	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:35		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	19:23	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-005
Sample Location:	G-10	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:48		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.86	µg/L	15	6/21/2022	19:35	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-006
Sample Location:	G-11	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:41		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.60	µg/L	15	6/21/2022	19:40	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-007							
Sample Location: G-12		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:42									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	19:46	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-008							
Sample Location: G-13		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:43									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	19:51	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-009							
Sample Location: G-14		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:45									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	19:57	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-010							
Sample Location: G-15		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:50									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	20:02	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-011							
Sample Location: G-22		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:59									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/21/2022	20:08	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-012							
Sample Location: G-24		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:57									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	10.7	µg/L	15	6/21/2022	20:13	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-013							
Sample Location: G-25		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:16									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.07	µg/L	15	6/22/2022	13:57	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-014							
Sample Location: G-26		Customer Sample Number:							
Sampled By: Client									
Sample Date/Time: 6/3/2022 5:18									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	24.9 **	µg/L	15	6/22/2022	14:05	JGW	4	2

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-015								
Sample Location: G-27		Customer Sample Number:								
Sampled By: Client										
Sample Date/Time: 6/3/2022 5:19										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	3.82	µg/L	15	6/22/2022	14:11	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-016								
Sample Location: G-28		Customer Sample Number:								
Sampled By: Client										
Sample Date/Time: 6/3/2022 5:20										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	3.59	µg/L	15	6/22/2022	14:16	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-017								
Sample Location: G-29		Customer Sample Number:								
Sampled By: Client										
Sample Date/Time: 6/3/2022 5:23										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	5.83	µg/L	15	6/22/2022	14:22	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220531059-018								
Sample Location: G-30		Customer Sample Number:								
Sampled By: Client										
Sample Date/Time: 6/3/2022 5:25										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	12.6	µg/L	15	6/22/2022	14:27	JGW	2	1	



Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-019
Sample Location:	G-31	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 6:00		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.57	µg/L	15	6/22/2022	14:32	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-020
Sample Location:	G-49	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:33		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	157 **	µg/L	15	6/22/2022	14:57	JGW	20	10

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-021
Sample Location:	G-53	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:30		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	15:08	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-022
Sample Location:	G-54	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:29		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	15:14	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-023
Sample Location:	G-55	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:15		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	15:19	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-024
Sample Location:	G-56	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:14		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/22/2022	15:25	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-025
Sample Location:	G-57	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 5:12		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.03	µg/L	15	6/22/2022	15:30	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-026
Sample Location:	G-58	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 6:20		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	316 **	µg/L	15	6/24/2022	11:13	JGW	40	20

Sample Matrix:	Drinking Water	Lab Sample Number:	220531059-027
Sample Location:	G-63	Customer Sample Number:	
Sampled By:	Client		
Sample Date/Time:	6/3/2022 6:16		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	56.1 **	µg/L	15	6/22/2022	16:09	JGW	8	4

NJ Lab ID# 14013 (Dover)

NJ Lab ID# 13033 (Marlboro)

\*\* Result does not meet NJDEP Limits.

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (\*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen  
 Susan VanVeen, Laboratory Manager

June 27, 2022



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220531059

Customer Name: West Milford High School  
 Location: 46 Highlander Drive  
 Address: 67 Highlander Dr.  
 West Milford, NJ, 07480  
 Customer Contact: Laura Tallia  
 Phone: Work/Cell 973-697-1700 ex 5071 /

Report to: Barbara Francisco  
 West Milford, NJ, 07480

Agra Environmental Services  
 90 1/2 West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

Matrix Abbreviations: DW - Drinking water, GW - Ground Water, RAW-GW - RAW Ground Water, WW/NPW - Wastewater, SL - Sludge, P - Pool, L - Lake

Asc./HCl Vials pH: \_\_\_\_\_  
 HCl Vials pH: \_\_\_\_\_  
 Na<sub>2</sub>S<sub>2</sub>O<sub>5</sub> pH: \_\_\_\_\_  
 HNO<sub>3</sub> pH: \_\_\_\_\_  
 H<sub>2</sub>SO<sub>4</sub> pH: \_\_\_\_\_  
 NaOH unpreserved pH: \_\_\_\_\_  
 other pH: \_\_\_\_\_

Page 1 of 3

Sample ID	Location	Collection Date	Time	PWSID#	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis
20531059-001	Field Blank	6-3-22	5:10 AM	X			DW	1	HNO3	Lead-1st Draw	Cl <sub>2</sub> or PO <sub>4</sub>
20531059-002	G-5	6-3-22	5:30 AM	X			DW	1	HNO3	Lead-1st Draw	pH / Temp
20531059-003	G-7	6-3-22	5:40 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-004	G-8	6-3-22	5:25 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-005	G-10	6-3-22	5:48 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-006	G-11	6-3-22	5:41 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-007	G-12	6-3-22	5:42 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-008	G-13	6-3-22	5:43 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-009	G-14	6-3-22	5:45 AM	X			DW	1	HNO3	Lead-1st Draw	
20531059-010	G-15	6-3-22	5:50 AM	X			DW	1	HNO3	Lead-1st Draw	

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013  
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
<i>Krissy Martin</i>	6/3/22	6:45	<i>J. Tallia</i>	6/3/22	6:46
<i>Laura Tallia</i>	6/3/22	11:07	<i>J. Tallia</i>	6-3-22	11:27
<i>[Signature]</i>	6-3-22	11:34	<i>[Signature]</i>	6-3-22	11:59
<i>[Signature]</i>			<i>[Signature]</i>		

Comments: *6-3-22 6:46 AM*

Date Faxed: \_\_\_\_\_ Invoice Number: \_\_\_\_\_

Is sample known to be hazardous? (circle one) Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220531059

Customer Name: West Milford High School      Report to: Barbara Francisco  
 Location: 46 Highlander Drive  
 Address: 67 Highlander Dr.      West Milford, NJ, 07480  
 Customer Contact: Laura Tallia  
 Phone: Work/Cell 973-697-1700 ex 5071 /

Matrix Abbreviations: DW - Drinking water    GW - Ground Water    RAW-GW - DW RAW-GW    WW/NPW - Wastewater    SL - Sludge    P - Pool    L - Lake    Page 2 of 3

Agra Environmental Services  
 90 1/2 West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

# Asc./HCl Vials    pH: \_\_\_\_\_  
 # HCl Vials    pH: \_\_\_\_\_  
 # Na<sub>2</sub>S<sub>2</sub>O<sub>5</sub>    Cl<sub>2</sub>: \_\_\_\_\_  
 # HNO<sub>3</sub>    pH: \_\_\_\_\_  
 # H<sub>2</sub>SO<sub>4</sub>    pH: \_\_\_\_\_  
 # NaOH    pH: \_\_\_\_\_  
 # unpreserved    \_\_\_\_\_  
 # other    \_\_\_\_\_

Sample ID	Location	Date	Time	Collection	PWSID#	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Field Analysis
20531059-011	G-22	6-3-22	5:54pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		Cl <sub>2</sub>
20531059-012	G-24	6-3-22	6:57pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		or
20531059-013	G-25	6-3-22	5:16pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		PO <sub>4</sub>
20531059-014	G-26	6-3-22	5:15pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		
20531059-015	G-27	6-3-22	5:14pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		
20531059-016	G-28	6-3-22	5:20pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		
20531059-017	G-29	6-3-22	5:23pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		
20531059-018	G-30	6-3-22	5:25pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		
20531059-019	G-31	6-3-22	6:00pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		
20531059-020	G-49	6-3-22	5:53pm	X		X	DW	DW	1	HNO3	Lead-1st Draw		

Are these samples for compliance? (circle one): Yes or **(No)**

NJDEP Laboratory Certification (Dover, NJ) #14013  
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Reporting Requirements (Check Box):  
 Standard     NJ Reduced     Other (Specify)

Cooler Temperature Upon Receipt at lab: \_\_\_\_\_

Sample Custody Exchanges (Please use full legal signature)		Date:	Time:	Received By:	Date:	Time:	Received By:
Relinquished By: <i>Dean Myrator</i>	Received By: <i>L. Tallia</i>	6/3/22	6:45	6/3/22	6:46	6/3/22	6:46
Relinquished By: <i>Laura Tallia</i>	Received By: <i>L. Tallia</i>	6/3/22	11:27	6/3/22	11:27	6/3/22	11:27
Relinquished By: <i>L. Tallia</i>	Received By: <i>L. Tallia</i>	6/3/22	14:34	6/3/22	14:34	6/3/22	14:34
Relinquished By: _____	Received By: _____	Date:	Time:	Received By:	Date:	Time:	Received By:

Comments: *Preserved in 40% HNO3*  
*6/06/22-554*

Date Faxed: \_\_\_\_\_  
 Invoice Number: \_\_\_\_\_

Is sample known to be hazardous? (circle one)  
 Yes or No



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220531059

Customer Name: West Milford High School  
 Location: 46 Highlander Drive  
 Address: 67 Highlander Dr.  
 West Milford, NJ, 07480  
 Customer Contact: Laura Tallia  
 Phone: Work/Cell 973-697-1700 ex 5071 /

Report to: Barbara Francisco  
 46 Highlander Drive  
 West Milford, NJ, 07480

Agra Environmental Services  
 90 1/2 West Blackwell Street  
 Dover, NJ 07801  
 Phone: (973) 989-0010  
 Fax: (973) 989-0156

Asc./HCl Vials pH: \_\_\_\_\_  
 HCl Vials pH: \_\_\_\_\_  
 H<sub>2</sub>SO<sub>4</sub> pH: \_\_\_\_\_  
 HNO<sub>3</sub> pH: \_\_\_\_\_  
 H<sub>2</sub>SO<sub>4</sub> pH: \_\_\_\_\_  
 NaOH pH: \_\_\_\_\_  
 unpreserved \_\_\_\_\_  
 other \_\_\_\_\_

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
220531059-021	G-53	6-3-22	5:30 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		
220531059-022	G-54	6-3-22	5:29 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		
220531059-023	G-55	6-3-22	5:15 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		
220531059-024	G-56	6-3-22	5:14 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		
220531059-025	G-57	6-3-22	5:12 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		
220531059-026	G-58	6-3-22	6:20 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		
220531059-027	G-63	6-3-22	6:16 AM	X	DW	DW	1	HNO <sub>3</sub>	Lead-1st Draw		

Project: BOE Lead Sampling

Collection: \_\_\_\_\_

PWSID# \_\_\_\_\_

for laboratory use only

Field Analysis

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

Standard \_\_\_\_\_

NJ Reduced \_\_\_\_\_

Other (Specify) \_\_\_\_\_

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: \_\_\_\_\_

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: *Ryan Monte* Date: 6/3/22 Time: 6:45 Received By: *J. Tallia* Date: 6/3/22 Time: 6:46

Relinquished By: *Ryan Tallia* Date: 6/6/22 Time: 11:07 Received By: *[Signature]* Date: 6/6/22 Time: 11:29

Relinquished By: *[Signature]* Date: 6/6/22 Time: 11:31 Received By: *[Signature]* Date: 6/6/22 Time: 1:09

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_ Received By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Comments: *Preserved with HNO<sub>3</sub> 1435 and 22 - 8.500*

Date Faxed: \_\_\_\_\_ Invoice Number: \_\_\_\_\_

Is sample known to be hazardous? (circle one) Yes or No